

Tennessee Law Enforcement Training Academy (TLETA)

Building Profile

Site Address:	3025 Lebanon Rd. Nashville, TN. 37214
Year Built:	1966
Size:	64,000 Square Foot
Type:	Offices, Dormitories, Gymnasium
Normal Hours:	24 hrs / 7 days



Energy Conservation Measures

- Pro-Active Facility Maintenance
- Chiller piping renovations for economizer operation
- LED Lighting retrofit on various interior spaces and exterior parking areas
- Sequence of control optimization based on Outside Air temperatures

Year to Date Performance for 12-Month Period Ending 06/2014

TLETA (Law Enfor. Training Acad)
Utility Cost and Savings Summary

Monthly Performance for 06/2014 Vs. 06/2013

Utility Service	Current Usage	Comp Yr Level	% Chg	Current Cost	Comp Yr Cost	% Chg	Cost/ SqFt/Yr	Monthly Savings	YTD Savings
Electricity	131,578	101,067	+ 30.2	\$9,793	\$7,074	+ 38.4	\$1.48	(\$2,271)	(\$27,101)
Natural Gas	485	1,919	- 74.8	\$733	\$1,756	- 58.3	\$0.64	\$1,314	\$2,511
Water	201	202	- 0.5	\$847	\$580	+ 46.0	\$0.10	(\$267)	(\$1,376)
Sewer	201	202	- 0.5	\$1,332	\$1,287	+ 3.5	\$0.21	(\$46)	(\$1,828)
Fire Protection	0	0	N/A	\$13	\$11	+ 20.0	\$0.00	(\$2)	(\$2)
Demand	282	244	+ 15.6	\$2,836	\$2,316	+ 22.4	\$0.47	(\$520)	(\$9,944)
Totals				\$15,555	\$13,024		\$2.89	(\$1,791)	(\$37,740)

Comparison Year ends 06/2013

Savings for Electricity based on current use per sqft vs. comp yr (adjusted for hdd)

Savings for Natural Gas based on current use per sqft vs. comp yr (adjusted for hdd)

Savings for Water based on current cost vs. comp yr

Savings for Sewer based on current cost vs. comp yr

