


**TOSHA**  
**25 MOST CITED CONSTRUCTION STANDARDS**  
 January 1, 2008–December 31, 2008



Rank	#Cited	Standard	Hazard Description
1	94	1926.501(b)(1)	No Fall Protection for Unprotected Sides and Edges Above 6 Feet
2	87	1926.453(b)(2)(v)	No Body Belt Worn When Working from an Aerial Lift
3	67	1926.404(f)(6)	No Permanent & Continuous Electrical Path to Ground
4	63	1926.503(a)(1)	No Training on Fall Hazards for Exposed Employees
5	52	1926.451(g)(4)(i)	Inadequate Guardrails on Open Sides and Ends of Scaffold Platforms
6	51	1926.454(a)	Untrained Employees Working on Scaffolds
7	47	1926.100(a)	No Head Protection Used Where There is Possibility of Head Injury
8	46	1926.451(e)(1)	Ladder Not Provided to Access Scaffold
9	44	1926.405(g)(2)(iv)	Strain Relief Not Provided on Flexible Cords
10	39	1926.652(a)(1)	Inadequate Cave-in Protection on Excavation Site
11	39	1926.451(f)(3)	Scaffolds Not Inspected by Competent Person Before Each Work Shift
12	39	1926.451 (g)(1)	No Fall Protection on Scaffolds 10 Feet or Higher
13	37	1926.50(c)	No One Trained in First Aid
14	35	1926.1053(b)(1)	Ladder Side Rails Do Not Extend Three Feet Above Upper Surface
15	33	1926.452(c)(2)	Scaffolds Not Properly Crossbraced
16	33	1926.451(b)(1)	Scaffold Platforms Not Planked or Decked
17	32	1926.451(c)(2)	No Baseplates and Mud Sills for Supported Scaffold Poles
18	30	1926.416(e)(1)	Worn or Frayed Electric Cords/Cables Used
19	25	1926.651(k)(1)	No Daily Inspections of Excavations by Competent Person
20	23	1926.501(b)(10)	No Fall Protection for Employees Working on Low-Slope Roofs
21	22	1926.451(f)(7)	No Competent Person for Erecting, Moving, Dismantling, or Altering Scaffolds
22	22	1926.405(b)(2)	No Covers on Pull Boxes, Junction Boxes, Fittings, or Outlet Boxes
23	20	1926.21(b)(2)	Employees Not Instructed in Recognizing & Avoiding Unsafe Conditions
24	19	1926.501(b)(11)	No Fall Protection While on Steep Roof
25	19	1926.405(a)(2)(ii)(I)	Flexible Cords/Cables Not Protected from Damage