



STATE OF TENNESSEE  
DEPARTMENT OF CORRECTION

**INVITATION TO BID # 32901-13314  
AMENDMENT # 1  
FOR WATER TREATMENT SERVICES**

DATE: 5/6/2024

ITB # 32901-13314 IS AMENDED AS FOLLOWS:

**1. State responses to questions and comments in the table below amend and clarify this ITB.**

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		<p>1. The following list of products are not products needed for the routine water treatment program and are not typically included in the water treatment contract. They are typically quoted only if needed. Will these be priced out separately only if needed?</p> <p>Related Water Treatment Products: Contractors shall provide products including, but not limited to, the following:</p> <ul style="list-style-type: none"> <li>•Non-acid concentrated coil cleaner shall dilute 100-150 square feet per gallon.</li> <li>•Condensate pan tablets containing no chlorine which can cause rust and corrosion. Condensate pan tables shall be non-foaming and shall control mud, silt, and lint build-up in pans to prevent clogging drains.</li> <li>•Self-rinsing evaporator coil cleaner shall contain no free caustics or acids and shall be suitable as a filter coating.</li> <li>•De-foamer shall be silicone solution for use in controlling foam in boiler, cooling towers, and closed loops during cleaning, desaling, or normal operation.</li> <li>• Closed loop cleaner shall be concentrated liquid cleaner specifically designed and labeled for cleaning of rust, mill scale, and sludge from closed loop systems.</li> <li>•De-scaler shall be concentrated inhibited acid specifically designed and labeled for the</li> </ul>	<p>Per page 2 on scope of work on contract, the Contractor shall determine the amount of chemicals needed to bring the system within the recommended and acceptable water treatment parameters during the initial visit and during each monthly visit. Respondents should include the cost of chemicals in their monthly price. Chemicals will not be priced out separately.</p>

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		aggressive removal of scale deposits from metal surfaces without harms to the protective galvanized coating. •Socket or filters to be replaced as needed, if applicable.	

2. **ITB Amendment Effective Date.** The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.