



---

---

**TOWN OF COLLIERVILLE**  
**GENERAL SERVICES DEPARTMENT**  
Procurement Division  
MEMORANDUM



---

**TO:** ALL TC2024-18 PLAN HOLDERS  
**FROM:** TERRI SPEARS, PROCUREMENT SPECIALIST, SR.  
**SUBJECT:** ADDENDUM #2  
**DATE:** 6/4/2024  
**CC:** TC2024-18 FILE

---

ADDENDUM NO. 2

The **BID OPENING DATE** for BID TC2024-18 Shelton Road WWTP Outfall has been moved to **JUNE 12, 2024 @ 2:00:00 p.m. (local time).**

**REMINDER: Bidders must bid using the REVISED BID FORM 05.17.24 for their Bid Response as provided in Addendum 1.**

**QUESTION:** More information is requested regarding the erosion and sediment control measures to be bid as a lump sum for this project. What is the estimated length of the turbidity curtain? Silt fence?

**ANSWER:** The only EPSC measures we are showing are the turbidity curtain and the stream diversion (coffer dam). We do not anticipate silt fence would be implemented with all the work happening on the riverbank slope. The turbidity curtain and coffer dam should prevent silt from leaving the site. The turbidity curtain measures ~280 LF, so we can estimate it at 300 LF to be conservative.

Vendor shall acknowledge receipt of this Addendum #2 consisting of 1 page by signing and dating below. Please return via email to [tocpurchasing@colliervilletn.gov](mailto:tocpurchasing@colliervilletn.gov) or via fax to (901) 457-2258.

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date