
TO**Name:** Plan Holders

PROJECT**Name:** Alamo Sewer System Improvements Phase I**A2H #:** 21451.01

DETAILS**Addendum #:** 2**Date of Issuance:** 7/3/24**Sent Via:** Email**Total Pages:** 2

This addendum modifies the original drawings/specifications and shall be included as part of the contract documents. Items in this addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the addendum.

The bidder shall acknowledge receipt of this addendum by placing the addenda dates and addenda numbers on the outside of their proposal envelope and in the place provided on the bid form. In addition, the bidder shall confirm receipt of this addendum by returning the signature page with appropriate initial where indicated via email (Bidding@a2h.com) or fax (901) 373-4002. Failure to do so may subject the bidder to disqualification.

ACKNOWLEDGEMENT OF RECEIPT**Name:** _____**Company:** _____**Signature:** _____**Date:** _____

CLARIFICATIONS

1. Can you please provide manhole depths for design calculations?
 - *We do not have manhole inspection reports that provide the depth of each manhole.*
2. The CIPP spec initially mentions the curing of the CIPP via "...a suitable heat source..." However, it later references curing by hot water, but does not mention steam. Therefore, will the Owner please formally allow air inversion/steam curing as a CIPP installation option?
 - *Steam curing will be allowed.*
3. The CIPP Spec mentions protruding taps are incidental to the CIPP lining. However, it also mentions an effort shall be made to identify protruding taps in the bid form. Given there is no protruding tap bid item and none are called out in the Rehabilitation Scope table in the drawings, shall the Contractor assume no protruding taps are expected? Furthermore, in the event they are encountered shall the Contractor assume this would be a change order?
 - *If the preliminary CCTV reports, attached to the specifications, indicate there is a protruding tap, the necessary repair has been counted in the point repair line item and will be paid accordingly. The contractor should not include cost for point repairs or protruding taps as incidental to the CIPP lining.*

CHANGES TO SPECIFICATIONS

None

CHANGES TO DRAWINGS

None

ATTACHMENTS

None

Sincerely,
A2H, Inc.



Travis Martin, PE
Senior Associate Principal