

REQUEST FOR INFORMATION

- **Contract Number: CNR048**
- **Project: Interstate 24, Bridge Replacement over Spring Street and Oldham Street**
- **Date:**
- **Question:**

1. REF: Drawings BR-122-54B, BR-122-55B, BR-122-56B, BR-122-57B

Please provide missing information from Oldham Street Bents 1,2,3,4 :

- i. Pile-cap thickness
 - ii. Pile embedment
 - iii. Pile locations
 - iv. Please provide missing section D-D on Drawing BR-122-55B.
2. Please provide missing information BR-122-24 End View section - Pile embedment
 3. Please provide H-pile installation records from Spring Street and Oldham Street bridges due to lack of boring logs at the proposed pile-cap locations.

- **TDOT Response:**

1. A plan revision will be issued with these dimensions.
2. Pile embedment is 12 inches.
3. H-pile installation records for the existing bridges will be provided if available.

* Please email questions to Jamie Fitzpatrick at Jamie.Fitzpatrick@tn.gov.